SUBMITTAL RECORD_	
JOB	
LOCATION	
SUBMITTED TO	
SUBMITTAL PREPARED BY	
APPROVED BY	
DATE	



Submittal Form IADVP Vision Panel Insulated Access Doors - Hinged

Servi

SUGGESTED SPECIFICATIONS

Service openings shall be provided in ducts adjacent to each fire door, fire damper, smoke damper and smoke detector. Horizontal ducts and plenums shall be provided with ser-

vice openings to facilitate cleaning the duct of accumulations of dust and combustible materials. Service openings shall be placed at approximately 20 foot intervals along the duct and at the base of each vertical riser. Service openings shall be sized _____ x____ and shall incorporate access doors coded _____ as manufactured by Duro Dyne Corporation.

CONSTRUCTION

Door Frame: 24 ga. galvanized steel. Conforms to ASTM-A-591. **Door Face:** 24 ga. galvanized steel. Conforms to ASTM-A-591. **Insulation:** Fiberglass blanket. Insulation 1" Micro-Airc M/F Type-

475 R Value 7.7.

Seals: Door to Frame/Frame to Door-Neoprene gasket. Conforms to ASTM-D 1056-68. Temperature range -20°F to 225°F .26 K Factor. **Latches:** Single Camlock action on all hinged doors 12" square and under. Dual latches on larger hinged sizes. Latches constructed of zinc plated cold rolled steel. Steel conforms to ASTMA-A-366. Plating conforms to ASTMA-164-55.

Hinge: Continuous Aluminum Piano Hinge. **Vision Panel:** .125 Plexiglass Vision Panel.

Item#	Code	Cut hole in duct	Vision Panel Size
6381	IADVP6x6	4-3/4" x 4-3/4"	3"x 3"
6382	IADVP8x8	6-3/4" x 6-3/4"	3"x 3"
6383	IADVP10x10	8-3/4" x 8-3/4"	4"x 4"
6384	IADVP12x12	10-3/4" x 10-3/4"	5"x 5"
6385	IADVP14x14	12-3/4" x 12-3/4"	5"x 5"
6386	IADVP16x16	14-3/4" x 14-3/4"	6" x 6"
6387	IADVP18x18	16-3/4" x 16-3/4"	6"x 6"
6388	IADVP20x20	18-3/4" x 18-3/4"	8" x 8"
6389	IADVP24x24	22-3/4" x 22-3/4"	10" x 10"

Cam Lock only also available, code IADCVP.

Duct INSULATION-INSIDE Starter Tab Duct INSULATION-OUTSIDE Poam Gasket 24 Ga. Galvanized Door Frame 1" 1 1/2# Coated Fiberglass	
WITHOUT DUCT INSULATION	

vice openings to f

RELATED NFPA 90A & 90B STANDARDS

DESCRIPTIONPeriodic inspection and testing of fire and smoke dampers and

detectors in ductwork is a standard safety procedure. Easy

access to these devices as well as providing a means of removing dust accumulation can be provided by the installation of

Vision Panel Hinged Access Doors from Duro Dyne. These doors incorporate an integral frame which readily fastens to the

duct work as well as a camlock latching system for easy entry.

2-1.4 Duct Access and Inspection Provisions.

- **2-1.4.1** A service opening or telescoping or removable duct section shall be provided in ducts adjacent to each fire door, fire damper, smoke damper and smoke detector. The opening shall be large enough to permit maintenance and resetting of the device.
- **2-1.4.1** Service openings, telescoping or removable duct sections shall be identified with letters no less than 1/2 in. (1.27 cm) in height to indicate the location of the fire protection device(s) within.
- **2-1.4.3** Horizontal ducts and plenums shall be provided with service openings (see 2-1.4.1) to facilitate cleaning the duct of accumulations of dust and combustible materials. Service openings shall be placed at approximately 20 ft. (6.1-m) intervals along the duct and at the base of each vertical riser.

Exception No. 1: Removable air outlet or air inlet devices of adequate size may be accepted in lieu of service openings.

Exception No. 2: Service openings may be omitted in supply ducts when the supply air has previously passed through air filters or water spray.

Exception No. 3: Service openings are not required when all the following conditions prevail:

- (a) The occupancy does not produce combustible material such as dust, lint, greasy vapors, etc. Such occupancies include banks, office buildings, churches, hotels, and health care facilities (but not kitchens, service rooms, and manufacturing portions of such facilities).
- **(b)** The air inlets are at least 7 ft. (2.13m) above the floor or are protected by corrosion-resistant metal screens of at least 14 mes, installed at the inlets so that they will not draw papers, refuse, cigarettes or other combustible solids into the return air duct.
- (c) The minimum design velocity in the return duct from the particular occupancy is 1,000 ft/min. (508m/sec.).

Duro Dyne East Division, Bay Shore, NY 631-249-9000 Fax: 631-249-8346

Duro Dyne Midwest Division, Fairfield, OH 513-870-6000 Fax: 513-870-6005

Duro Dyne West Division, Fontana, CA 562-926-1774 Fax: 562-926-5778

Duro Dyne Canada, Lachine, Quebec, Canada 514-422-9760 Fax: 514-636-0328

www.durodyne.com E-mail: durodyne@durodyne.com

©2016 DURO DYNE CORPORATION Printed in the USA 07/16 BO008461