

SUBMITTAL RECORD _____
 JOB _____
 LOCATION _____
 SUBMITTED TO _____
 SUBMITTAL PREPARED BY _____
 APPROVED BY _____
 DATE _____



Submittal Form WITLV-AS / BWITLV-AS Water Based Duct Liner Adhesive

DESCRIPTION

WITLV-AS is a premium, multi-use, water based, non-flammable, UL Classified duct liner and insulation adhesive specifically engineered and formulated for all types of spray, roller, brush or extrusion applications. Also available in black as BWITLV-AS.

FEATURES

- Water Based
- Non-Flammable
- Excellent Tack & Adhesion
- Excellent Adhesion to Metal
- Excellent Adhesion to Fibrous and Foil Backed Duct Insulation
- Airless Sprayable
- Brushable
- Rollable
- Great Coverage
- Seal Cut Edges
- Mild Odor
- Immediate Tack
- Water Resistant
- Low VOC
- Easy Clean-Up
- UL 723 Classified
- LEED Compliant

TYPICAL PROPERTIES

Base: Synthetic latex
Consistency: Low viscosity liquid
Solvent: Water
Solids: Approx 40%
Weight: 9.5 lbs./gallon
Color: White or Black
Odor: Mild
VOC: 2.4 g/l
Viscosity: >2000 cps
Flammability: Non-Flammable
Effect of Freezing: No damage - 5 Cycles
Storage Life: One year (unopened)
Clean With: Warm Water/Soap when wet; solvent when dry
Method of Application: Brush, roller, standard spray or roller coated
Preparation: Surface must be dry, dirt, oil and grease free
Coverage: Up to 530 sq. ft. / gal depending on application
Water Resistance: Good
Mildew Resistance: Mold & Mildew resistant
Application Temperature: 40F °F - 110 °F
Service Temperature: -20F °F - 200 °F
Bond Time: 2-10 minutes
Dry Time: 20-40 minutes*
 * May vary according to temperature and humidity

RELATED SMACNA RECOMMENDATIONS*

7.4 Installation Standards For Rectangular Ducts Using Flexible Liner

S2.3 Each layer of duct liner shall be attached with 90 percent coverage of adhesive at the liner contact surface area.

S2.4 All transversely oriented edges of liner not receiving metal nosing shall be coated with adhesive. Liner shall be neatly butted without gaps at transverse joints and shall be coated with adhesive at such joints before butting.

S2.6 Ducts with interior widths of 8 in. (203 mm) or less do not require mechanical fasteners in addition to adhesive.

**From SMACNA HVAC Duct Construction Standards Metal and Flexible • Third Edition • 2005*

- **UL 723 Classified**
- **LEED Compliant SCAQMD Rule 1168**
- **Conforms to Requirements of:**
NFPA 90A and 90B
FDA, USDA and EPA Standards
ASTM C-916
ASTM E-84

ITEM#	CODE	DESCRIPTION
5106	WIT5LVAS	WITLV-AS White 5 Gallon Pail
5107	WIT50LVAS	WITLV-AS White 50 Gallon Drum
5127	BWIT5LVAS	BWITLV-AS Black 5 Gallon Pail
5128	BWIT50LVAS	BWITLV-AS Black 50 Gallon Drum

SUGGESTED SPECIFICATIONS

All metal duct shall be lined according to SMACNA HVAC Duct Construction Standard. Each layer of duct liner shall be attached with 90% coverage of adhesive at the liner contact surface area. Adhesive shall be UL classified for surface burning characteristics and be water based. Adhesive shall be WITLV-AS or BWITLV-AS as manufactured by Duro Dyne Corporation.



File # R5286

ADHESIVES SURFACE BURNING CHARACTERISTICS 4KW4

FLAME SPREAD.....0
SMOKE DEVELOPED.....0

Also classified in accordance with ASTM D1929-96



©2016 DURO DYNE CORP.
 Printed in the USA 8/16
 BO005427

Duro Dyne East Division, Bay Shore, NY	631-249-9000	Fax: 631-249-8346
Duro Dyne Midwest Division, Fairfield, OH	513-870-6000	Fax: 513-870-6005
Duro Dyne West Division, Fontana, CA	562-926-1774	Fax: 562-926-5778
Duro Dyne Canada, Lachine, Quebec, Canada	514-422-9760	Fax: 514-636-0328
www.durodyne.com E-mail: durodyne@durodyne.com		